



ELLIOTT ELECTRIC SUPPLY

We Deliver...Lower Cost, Quality Products, & Personal Service

2310 N. Stallings Dr.
75964-0000, TX Nacogdoches
Phone: 936-569-7941
Fax: 936-560-4685



CVS2150XMM CVS 2P 150AS 42KA 240 Vac Load Terms W/Hardware *Eaton Corp*

Catalog Number	CVS2150XMM
Manufacturer	Eaton Corp
Description	Eaton Type CV Molded Case Circuit Breaker, Molded Case Circuit Breaker, 150 A, 42 Kaic, Two-Pole, #6 - 4/0 Al/Cu, CV, #4/0 Kcmil Maximum Load, Includes Mounting Kit
Weight per unit	2.8 (lbs/each)
Product Category	2 Pole

Features

Current Rating	150 A
dimensions	7.5000 IN X 3.5000 IN X 5.0000 IN
interrupt rating	42 kAIC
Poles	2

Descriptions

Description	CVS 2P 150AS 42KA 240 VAC LOAD TERMS W/HARDWARE
extra long description	ETN CVS2150XMM CVS 2 POLE 150 AMPS
Features	Eaton's main circuit breakers are used in a variety of applications including the main or emergency disconnect on the outside of a house, a tenant main breaker in group metering stacks and feed-through lug blocks specifically designed for sub-feeding from an existing panel. Main breakers are available with a variety of accessories including shunt trip, bell alarms and auxiliary switches.
Long Description	Eaton Type CV Molded Case Circuit Breaker, Molded case circuit breaker, 150 A, 42 kAIC, Two-pole, #6 - 4/0 Al/Cu, CV, #4/0 kcmil maximum load, Includes mounting kit
Product Type	CVS 2 Pole 150 Amps 42KA 240 Vac

Manufacturer Information

Brand	Eaton
GTIN	00786685705903
Manufacturers Part Number	CVS2150XMM
UPC	786685705903

Taxonomies, Classifications, and Categories

Category Description	MOLDED CASE BREAKERS
Type	Tenant main breaker

Packaging

Carton	1
Weight Per each	2.75



ELLIOTT ELECTRIC SUPPLY

We Deliver...Lower Cost, Quality Products, & Personal Service

2310 N. Stallings Dr.
75964-0000, TX Nacogdoches
Phone: 936-569-7941
Fax: 936-560-4685

Uses, Certifications, and Standards

Application

Marine Vessels and Equipment - Marine Vessels and Equipment -
OtherOtherGeneration - Renewable Energy - Alternative
EnergyGeneration - Conventional Energy - Conventional
EnergyDatacenters - IT Space: CI and Hyper Converged

standard

CSA Std. C22.2 No. 5,UL 489