

Elliott Electric Supply

We Deliver...Lower Cost, Quality Products, & Personal Service

2310 N. Stallings Dr. 75964-0000, TX Nacogdoches Phone: 936-569-7941 Fax: 936-560-4685

ħ	đ				
11	8			a	h
ч	٠.		34		Ζ.
ę	-	~~~	~~	-	2
1	1	T			
. 18	10.1	- 20			

STAG6 2" Alu Ins Ground Hub Crouse-Hinds

Catalog Number	STAG6		
Manufacturer	Crouse-Hinds		
Description	Eaton Crouse-Hinds Series Myers Ground Hub, Aluminum, 2"		
Weight per unit			
Product Category	Aluminum		
eatures			
connection	Threaded		
dimensions	3.2300 IN X 2.2400 IN X 3.2300 IN		
Material	360 Aluminum		
Material, Color, and Finish			
Finish	Natural		
Dimensions and Weight			
Size	2 in		
Descriptions			
Description	2" ALU INS GROUND HUB		
extra long description	MYERS STAG 6 CH MYERS 2 ALUM GROUND		
Features	Crouse-Hinds series Myers hubs are used in the termination of electrical circuits through wall of an enclosure. They are designed for use indoors or outdoors with rigid conduit and IMC and they are ideal for pharmaceutical, chemical and food processing, pulp/paper, nuclear, solar and commercial construction applications.		
Long Description	Eaton Crouse-Hinds series Myers ground hub, Aluminum, 2"		
Product Type	CH Myers 2 Alum Ground Hub		
Special Features	Vibration Proof, Ground Wire Size 8 AWG (CSA), 4 AWG (UL), Weight 45 Lb per 100		
Manufacturer Information			
Brand	Eaton		
GTIN	00784731101105		
Manufacturers Part Number	STAG 6		
UPC	784731101105		
axonomies, Classifications, and (Categories		
Category Description	Watertight Hub, 3-PIECE COUPLINGS, THREADLESS COUPLINGS AND THREADLESS CONNECTOR		
Туре	Ground Hub		



Elliott Electric Supply

We Deliver...Lower Cost, Quality Products, & Personal Service

2310 N. Stallings Dr. 75964-0000, TX Nacogdoches Phone: 936-569-7941 Fax: 936-560-4685

Packaging

Carton	
Package	10
Weight Per each	0.42

Uses, Certifications, and Standards

Application	Commercial / Institutional Buildings / Structures - Commercial /		
Enclosure	Institutional Buildings / Structures - Other NEMA 2/3/3R/4/4X/12		
standard	UL 514B, CUL, CSA C22.2		