



MILBANK
ENERGY AT WORK

U3862



Catalog Number	U3862
Marketing Product Description	60 Ampere Fused Alternating Current Disconnect Pull Out
UPC	784572586932
Length (IN)	3.107
Width (IN)	5.2
Height (IN)	9.25
Weight (LB)	4
Brand Name	Milbank
Type	Air Conditioner Disconnect
Special Features	10 Horse Power
Application	Metering Accessory
Standard	UL Listed;Type 3R
Voltage Rating	Up to 240 Volts Alternating Current
Amperage Rating	60 Ampere
Interrupt Rating	10,000 Ampere Interrupting Capacity
Number Of Poles	2
Trip Type	Thermal Overload and Short Circuit Current
Contact Configuration	Pull Out
Contact Rating	60 Ampere Up to 240 Volts Alternating Current
Connection	Pullout

Enclosure	Painted Steel
Mounting	Surface Mount
Size	3.107L x 5.2W x 9.25H
Conduit Connection	Knockouts

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.



MILBANK
ENERGY AT WORK

U3862



Catalog Number	U3862
Marketing Product Description	60 Ampere Fused Alternating Current Disconnect Pull Out
UPC	784572586932
Length (IN)	3.107
Width (IN)	5.2
Height (IN)	9.25
Weight (LB)	4
Brand Name	Milbank
Type	Air Conditioner Disconnect
Special Features	10 Horse Power
Application	Metering Accessory
Standard	UL Listed;Type 3R
Voltage Rating	Up to 240 Volts Alternating Current
Amperage Rating	60 Ampere
Interrupt Rating	10,000 Ampere Interrupting Capacity
Number Of Poles	2
Trip Type	Thermal Overload and Short Circuit Current
Contact Configuration	Pull Out
Contact Rating	60 Ampere Up to 240 Volts Alternating Current
Connection	Pullout

Enclosure	Painted Steel
Mounting	Surface Mount
Size	3.107L x 5.2W x 9.25H
Conduit Connection	Knockouts

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.