



**MILBANK**  
ENERGY AT WORK

## U9581-RL-QG



<b>Catalog Number</b>	U9581-RL-QG
<b>Marketing Product Description</b>	5 Terminal Ringless Small Hub Open Quadplex Ground Lever Bypass
<b>UPC</b>	784572310568
<b>Length (IN)</b>	4.844
<b>Width (IN)</b>	13
<b>Height (IN)</b>	19
<b>Brand Name</b>	Milbank
<b>Type</b>	Ringless Meter Socket
<b>Application</b>	Meter Socket
<b>Standard</b>	UL Listed;Type 3R
<b>Voltage Rating</b>	600 Volts Alternating Current
<b>Amperage Rating</b>	200 Continuous Ampere
<b>Phase</b>	1 Phase
<b>Frequency Rating</b>	60 Hertz
<b>Size</b>	4.844L x 13W x19H
<b>Number Of Cutouts</b>	0
<b>Cutout Size</b>	No Main Breaker
<b>Cable Entry</b>	Overhead or Underground
<b>Terminal</b>	Lay in
<b>Insulation</b>	No Insulation
<b>Mounting</b>	Surface Mount

**Enclosure** G90 Galvanized Steel with Powder Coat Finish

**Jaw Quantity** 5 Terminal

**Bypass Type** Lever Bypass

**Number of Meter Positions** 1 Position

**Equipment Ground** Quadplex Ground





**Hub Opening** Small Hub Opening

**Line Side Wire Range** 6 AWG - 350 kcmil

**Load Side Wire Range** 6 AWG - 350 kcmil

**Number Of Receptacles** 0

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.



FEATURE TABLE		
ITEM	QTY	DESCRIPTION
A	5	U/L MNTG.EMBOSS
B	1	1/4" SOLID K.O.
C	1	1/4", 1/2" CONC. K.O.
D	2	1, 1 1/4", 1 1/2", 2", 2 1/2" CONC. K.O.
E	4	1 1/4", 1 1/2", 2", 2 1/2", 3" CONC. K.O.



**MILBANK**  
ENERGY AT WORK

Version:

**1**

**All dimensions are +/- 1/16".  
Drawing views are not to scale.**

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility, and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.



**MILBANK**  
ENERGY AT WORK

## U9581-RL-QG



<b>Catalog Number</b>	U9581-RL-QG
<b>Marketing Product Description</b>	5 Terminal Ringless Small Hub Open Quadplex Ground Lever Bypass
<b>UPC</b>	784572310568
<b>Length (IN)</b>	4.844
<b>Width (IN)</b>	13
<b>Height (IN)</b>	19
<b>Brand Name</b>	Milbank
<b>Type</b>	Ringless Meter Socket
<b>Application</b>	Meter Socket
<b>Standard</b>	UL Listed;Type 3R
<b>Voltage Rating</b>	600 Volts Alternating Current
<b>Amperage Rating</b>	200 Continuous Ampere
<b>Phase</b>	1 Phase
<b>Frequency Rating</b>	60 Hertz
<b>Size</b>	4.844L x 13W x19H
<b>Number Of Cutouts</b>	0
<b>Cutout Size</b>	No Main Breaker
<b>Cable Entry</b>	Overhead or Underground
<b>Terminal</b>	Lay in
<b>Insulation</b>	No Insulation
<b>Mounting</b>	Surface Mount

**Enclosure** G90 Galvanized Steel with Powder Coat Finish

**Jaw Quantity** 5 Terminal

**Bypass Type** Lever Bypass

**Number of Meter Positions** 1 Position

**Equipment Ground** Quadplex Ground




**Hub Opening** Small Hub Opening

**Line Side Wire Range** 6 AWG - 350 kcmil

**Load Side Wire Range** 6 AWG - 350 kcmil

**Number Of Receptacles** 0

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.



FEATURE TABLE		
ITEM	QTY	DESCRIPTION
A	5	U/L MNTG.EMBOSS
B	1	1/4" SOLID K.O.
C	1	1/4", 1/2" CONC. K.O.
D	2	1, 1 1/4", 1 1/2", 2", 2 1/2" CONC. K.O.
E	4	1 1/4", 1 1/2", 2", 2 1/2", 3" CONC. K.O.



**MILBANK**  
ENERGY AT WORK

Version:

**1**

**All dimensions are +/- 1/16".  
Drawing views are not to scale.**

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility, and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.