



ELLIOTT ELECTRIC SUPPLY

We Deliver...Lower Cost, Quality Products, & Personal Service

2310 N. Stallings Dr.
75964-0000, TX Nacogdoches
Phone: 936-569-7941
Fax: 936-560-4685



ZS108 ZS108 1/2 .375-.500 Cord Conn Hubbell--Killark

| | |
|------------------|--|
| Catalog Number | ZS108 |
| Manufacturer | Hubbell--Killark |
| Description | 1/2" Aluminum Cord Connector, Cord Range .375-.500, Blue |
| Weight per unit | 0.1000 (lbs/each) |
| Product Category | Cable & Cord Grips |

Material, Color, and Finish

| | |
|--------|-----------|
| Color | Silver |
| Finish | Untreated |

Dimensions and Weight

| | |
|------|----------------------------|
| Size | 1.13 in x 0.55 in x 1.1 in |
|------|----------------------------|

Descriptions

| | |
|------------------------|--|
| Description | ZS108 1/2 .375-.500 CORD CONN |
| extra long description | KLRK ZS108 ALUMINUM CORD CONN BLUE |
| Long Description | 1/2" Aluminum Cord Connector, Cord Range .375-.500, Blue |
| Product Type | Aluminum Cord Conn Blue |
| Special Features | Aluminum construction resists corrosion. Neoprene grommet seals out oil and moisture. Nylon retention ring ensures superior holding power. |

Manufacturer Information

| | |
|---------------------------|----------------|
| Brand | KILLARK |
| GTIN | 00783936973494 |
| Manufacturers Part Number | ZS108 |
| series | Z Series |
| UPC | 783936973494 |

Taxonomies, Classifications, and Categories

| | |
|----------------------|------------------------------|
| Category Description | CORD CONNECTORS & CORD GRIPS |
| Type | Straight Cord Connector |

Packaging

| | |
|-----------------|-----|
| Carton | 50 |
| Package | 1 |
| Weight Per each | 0.1 |



ELLIOTT ELECTRIC SUPPLY

We Deliver...Lower Cost, Quality Products, & Personal Service

2310 N. Stallings Dr.
75964-0000, TX Nacogdoches
Phone: 936-569-7941
Fax: 936-560-4685

Uses, Certifications, and Standards

Application

Use to secure and seal cords or cables entering enclosures or raceways. Z Series connectors are also suitable for use in hazardous locations per National Electric Code (Articles 501-4(b), 502-4(a&b), 503-3(a&b)). Consult these articles for sealing require

environmental conditions

Hazardous locations

nema rating

12;13;4;4X

standard

UL, CSA